


TITLE Declaration of Conformity – eJumbo LED Exit Sign, LiFePO4 Battery				
PREPARED: G Grover	CHECKED: Stephen Charlton	APPROVED: Stephen Charlton	DOCUMENT NUMBER: BPDC002	ISSUE: A
DATE: 26/07/18	DATE: 30/07/18	DATE: 30/07/18	DATE: 27/07/18	DATE: 27/07/18

Product covered by this declaration –

PEJLEMCM-1	PEJLLXCM-1	PEJLRFCM-1
PEJLEMCM-2	PEJLLXCM-2	PEJLRFCM-2
PEJLEMCM-3	PEJLLXCM-3	PEJLRFCM-3
PEJLEMCM-5	PEJLLXCM-5	PEJLRFCM-5
PEJLEMCM-6	PEJLLXCM-6	PEJLRFCM-6
PEJLEMWM-1	PEJLLXWM-1	PEJLRFWM-1
PEJLEMWM-2	PEJLLXWM-2	PEJLRFWM-2
PEJLEMWM-3	PEJLLXWM-3	PEJLRFWM-3

Product Description –

eJumbo LED Exit variants, Monitored & Non-monitored. Exit sign comprising metal base housing containing control gear, LED light source, LiFePO4 battery pack and diffuser.

Declaration –

The product listed above is designed and manufactured to comply with the relevant standards as listed below, provided it is correctly installed and maintained.

Applicable Standards –

AS/NZS 60598.1:2013	Luminaires General requirements and tests
AS/NZS 60598.2.22:2005	Luminaires Particular requirements - Luminaires for emergency lighting
AS/NZS 2293.3:2005	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS/NZS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment



Signature:

Signed for and on behalf of ABB Australia Pty Ltd

Name & position, as authorized by the issuer	Stephen Charlton, LBU R&D Manager - Australia
Date of Issue	30/07/2018