



Professional Scientific Solutions

VOC Content Test Certificate

Monday April 12th, 2010

Manufacturer: Everbuild Australasia (30 Faunce Street, Queanbeyan NSW 2620)

Sample Description: 125 one hour caulk-all colours

Tested: April 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3	125 One Hour Caulk- All Colours
Architectural sealant 250 grams per Litre as VOC content material	82 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	125 One Hour Caulk- All Colours
Architectural sealant 250 grams per Litre as VOC content material	82 grams per Litre as VOC content material

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1004-05