

# Fire Testing Certificate

*This is to certify that the product(s) described below were tested by  
Firelab Pacific Limited (IANZ Accreditation Number 675)  
in accordance with AS 1530.4-1997 and AS 4072.1-1992 on behalf of*

Firepro Systems Limited  
8 Botha Rd  
Penrose  
Auckland  
New Zealand

**Certificate Issued:** February 1999

**Certificate Number:** 55398

**Product Name:** Firepro B362D-730.

**Product Description:** Double width steel flushboxes protected with Firepro M730 intumescent, mounted in standard CSR Gyprock Fyrchek System F2 and System F6 plasterboard walls. The flushboxes can be mounted individually in either wall type, or back-to-back through an F6 wall.

**Tests Performed:** 25 June 1998, 15 September 1998.

The product(s) satisfied the following criteria for fire-resistance for the periods stated:

**Structural Adequacy:** Not applicable.

**Integrity:** No failure at 62 minutes (1 hour FRL plasterboard wall).  
No failure at 122 minutes (2 hour FRL plasterboard wall).

**Insulation:** No failure at 62 minutes (1 hour FRL plasterboard wall).  
No failure at 122 minutes (2 hour FRL plasterboard wall).

For the purpose of the Building Regulations in Australia this product achieved the following Fire Resistance Level (FRL).

**Fire Resistance Level:** -/60/60 (1 hour FRL plasterboard wall)  
-/120/120 (2 hour FRL plasterboard wall)

Firelab Pacific Limited test numbers 31173 and 31193.



John Dibley  
Firelab Pacific Limited  
PO Box 12-907, Penrose, Auckland, New Zealand.



International Accreditation New Zealand (IANZ) has a Mutual Recognition Agreement (MRA) with the National Association of Testing Authorities, Australia (NATA), such that both organisations recognise accreditations by IANZ and NATA as being equivalent. Users of test reports/certificates are recommended to accept test reports/certificates in the name of either accrediting body.